



## Connector block boxes: Surface-box 3M Next

### 09983.N

System infrastructure / Enclosures and control units / Connector block boxes  
/ Surface mounting

### Surface-box 3M Next

3-module surface mounting box, 35/45 mm depth, for Eikon, Idea and Plana with relevants mounting frame and cover plates, Next



### Product Status

2 - Will be discontinued


### Minimum order quantity

10 NR


## Drawings



Space view



Backside view



3D View

Technical data

- **Class group:** Connection material (electrotechnical)
- **Class:** Box/housing for surface mounting on the wall/ceiling
- **Max. conductor cross section:** 0
- **Equipped with:** None
- **Shape:** Rectangular
- **Mounting method:** Wall-/ceiling mounting
- **Mounting in the soil:** No
- **Mounting under water:** No
- **For tube diameter:** 20/25 mm
- **Inlet from the rear:** Yes
- **Length:** 87,10 mm
- **Width:** 122,10 mm
- **Depth:** 46,00 mm
- **Diameter:** 0 mm
- **Tackable:** No
- **Number of inlets:** 4
- **Type of housing feed-through:** None
- **Material:** Plastic
- **Halogen free:** Yes
- **Surface protection:** Untreated
- **Colour:** Grey
- **Degree of protection (IP):** IP20
- **Cover model:** Other
- **Transparent cover:** No
- **Cover attachment:** Screwed
- **Castable:** No
- **With casting compound:** No
- **Sealable:** No
- **Rated insulation voltage Ui:** 450 V
- **Circuit integrity:** None
- **With screening:** No
- **Weatherproof:** No
- **Operating temperature:** 0 - 60 °C
- **Explosion-tested version:** No
- **For Ex-zone gas:** None
- **For Ex-Zone dust:** None

Certifications

- 00. CE Marking - EU
- 37. Marking - Morocco

Packaging



<b>Code</b>	8007352290891	<b>Code</b>	8007352290907
<b>Quantity</b>	1 NR	<b>Quantity</b>	10 NR
<b>Dim.</b>	12.1x8.4x4.5 [cm]	<b>Dim.</b>	28.6x24.8x9.6 [cm]
<b>Weight</b>	80.33 [g]	<b>Weight</b>	946 [g]

Legal

Vimar reserves the right to change at any time and without notice the characteristics of the products reported. Installation should be carried out by qualified staff in compliance with the current regulations regarding the installation of electrical equipment in the country where the products are installed. For the terms of use of the information on the product info sheet see [Conditions of Use](#).