



ARKÉ: 1P NO 10A cord-operated pushbutton white

19052.B

Wiring devices / Traditional wiring devices / ARKÉ / Devices

1P NO 10A cord-operated pushbutton white

1P NO 10 A 250 V~ cord-operated push button, with 1,5 m cord, white

Product Status

3 - Active


Minimum order quantity

20 NR


Video

- [Arké lives in your time](#)

Drawings



Space view



Backside view



3D View



Gallery



Technical data

- **Class group:** Domestic switching devices
- **Class:** Push button
- **Assembly arrangement:** Modular device for domestic switching devices
- **Model:** Other
- **Method of operation:** Push button
- **Number of rockers:** 0
- **Number of modules (module system):** 100
- **Number of poles:** 1
- **Nominal voltage:** 250 V
- **Rated current:** 10,00 A
- **With lighting:** No
- **Feedback-signal contact:** No
- **Mounting method:** Flush-mounted
- **Type of fastening:** Engage (snap)
- **Material:** Plastic
- **Material quality:** Thermoplastic
- **Halogen free:** Yes
- **Surface protection:** Untreated
- **Surface finishing:** Matt
- **Colour:** White
- **RAL-number (similar):** 9016
- **Transparent:** No
- **Label space/information surface:** Yes
- **Suitable for degree of protection (IP):** IP40
- **Device width:** 22,30 mm
- **Device height:** 49,00 mm
- **Device depth:** 38,50 mm

Certifications

- 00. CE Marking - EU
- 01. IMQ - Italy ([download](#))
- 10. EAC Eurasian Customs Union
- 14. TSE - Turkey
- 28. NSW - Australia ([download](#))
- 29. QCERT - Colombia
- 36. ISI - India
- 37. Marking - Morocco
- 43. UKCA mark - Great Britain
- 96. Electrotechnical expert ([download](#))
- 99. WEEE Directive ([download](#))

Packaging



Code 8007352455092
Quantity 1 NR
Dim. 6x2.8x5.3 [cm]
Weight 33.3 [g]

Code 8007352455108
Quantity 20 NR
Dim. 28.1x13.1x6 [cm]
Weight 745.5 [g]

Code 8007352626133
Quantity 240 NR
Dim. 38.5x29x30 [cm]
Weight 8,844.8 [g]

Legal

Vimar reserves the right to change at any time and without notice the characteristics of the products reported. Installation should be carried out by qualified staff in compliance with the current regulations regarding the installation of electrical equipment in the country where the products are installed. For the terms of use of the information on the product info sheet see [Conditions of Use](#).