



Shared components: Frame for RF device grey

20507

Smart systems&products / Smart switch&sound / Shared components /
Mounting frames

Frame for RF device grey

Frame for surface mounting of EnOcean, Bluetooth, ZigBee radiofrequency devices, to complete with Eikon or Plana 2-central-module or 2-module cover plates, grey

- The honeycomb structure gives structural strength
- The slots in the corners enable fixing to the panel
- The hooking teeth encourage fixing in series for the installation of multiple modules
- Thanks to the central slots, the support can be fixed onto the wall level



Product Status

3 - Active

Minimum order quantity

10 NR

You may also be interested in




07937 - Screw for frame
fixing - 35mm




07939 - Screw for frame
fixing - 50 mm


Drawings



Space view



Backside view



3D View

Technical data

- **Class group:** Domestic switching devices
- **Class:** Holder for modular domestic switching devices
- **Model:** Flush-mounted
- **Mounting method:** Mounting with screw
- **Mounting method of the module inserts:** Front side
- **Mounting direction:** Horizontal and vertical
- **Number of modules horizontal (module system):** 2
- **Number of modules vertical (module system):** 1
- **With built-in installation box:** No
- **With screws:** No
- **Suitable for mounting in round junction box 60 mm:** Yes
- **Flush-mounted installation:** Yes
- **Suitable for subfloor installation duct box:** No
- **Suitable for wall duct:** No
- **Suitable for mounting on DIN-rail 35 mm:** No
- **Material:** Plastic
- **Material quality:** Thermoplastic

Certifications

- 00. CE Marking - EU
- 29. QCERT - Colombia

Packaging



Code 8007352362710
Quantity 1 NR
Dim. 11.3x7.3x0.9 [cm]
Weight 26.3 [g]



Code 8007352362727
Quantity 10 NR
Dim. 13.9x11.9x7.4 [cm]
Weight 309.2 [g]



Code 8007352647541
Quantity 200 NR
Dim. 38.5x29.5x25 [cm]
Weight 6,640 [g]

Legal

Vimar reserves the right to change at any time and without notice the characteristics of the products reported. Installation should be carried out by qualified staff in compliance with the current regulations regarding the installation of electrical equipment in the country where the products are installed. For the terms of use of the information on the product info sheet see [Conditions of Use](#).