



Junction boxes: IP44 junction box 80x80x40mm

V55003

System infrastructure / Enclosures and control units / Junction boxes /
Surface mounting

IP44 junction box 80x80x40mm

Surface mounting junction box with cable entries, snap closed cover, RAL
7035 grey. Dimensions 80x80x40 mm



Product Status

3 - Active

Minimum order quantity

6 NR


Technical data

- **Class group:** Connection material (electrotechnical)
- **Class:** Box/housing for surface mounting on the wall/ceiling
- **Max. conductor cross section:** 0
- **Equipped with:** None
- **Shape:** Square
- **Mounting method:** Wall-/ceiling mounting
- **Mounting in the soil:** No
- **Mounting under water:** No
- **For tube diameter:** 20/25 mm
- **Inlet from the rear:** No
- **Length:** 80,00 mm
- **Width:** 103,00 mm
- **Depth:** 44,00 mm
- **Diameter:** 0 mm
- **Tackable:** No
- **Number of inlets:** 6
- **Type of housing feed-through:** Trimmable step membrane
- **Material:** Plastic
- **Halogen free:** No
- **Surface protection:** Untreated
- **Colour:** Grey
- **Degree of protection (IP):** IP44
- **Cover model:** Blind cover
- **Transparent cover:** No
- **Cover attachment:** Screwed
- **Castable:** No
- **With casting compound:** No
- **Sealable:** No
- **Rated insulation voltage Ui:** 450 V
- **Circuit integrity:** None
- **With screening:** No
- **Weatherproof:** Yes
- **Operating temperature:** 0 - 60 °C
- **Explosion-tested version:** No
- **For Ex-zone gas:** None
- **For Ex-Zone dust:** None

Certifications

- 00. CE Marking - EU
- 01. IMQ - Italy ([download](#))
- 43. UKCA mark - Great Britain
- 96. Electrotechnical expert ([download](#))

Packaging



8 007352 077003

Code 8007352077003
Quantity 1 NR
Dim. 10.4x10.4x4.4 [cm]
Weight 71 [g]



8 007352 077010

Code 8007352077010
Quantity 6 NR
Dim. 10.4x10.4x26.5 [cm]
Weight 428 [g]



8 007352 115712

Code 8007352115712
Quantity 54 NR
Dim. 38.5x29x30 [cm]
Weight 4,400 [g]

Legal

Vimar reserves the right to change at any time and without notice the characteristics of the products reported. Installation should be carried out by qualified staff in compliance with the current regulations regarding the installation of electrical equipment in the country where the products are installed. For the terms of use of the information on the product info sheet see [Conditions of Use](#).